

Date _____

Example Inspection Form
0-000-000-0000

Engine S/N _____

kW _____

Manufacturer _____

Model _____

Spec _____

Customer _____ Location _____

Gen Manufacturer _____ Model _____

Spec _____ Arrangement _____ S/N _____

Engine

- Oil level _____
- Batt voltage _____
- Batt volt drop _____
- Battery age _____
- Battery charger _____
- Alt Voltage _____
- Battery cables _____
- Fuel level _____
- Day tank OK? _____
- Radiator _____
- Coolant cond _____
- Hoses _____
- Belts _____
- Pump _____
- Eng temp (cold) _____
- Coolant heater _____

- Air cleaner _____
- Start OK? _____
- Starter _____
- Engine speed _____
- Governor _____
- Exhaust system _____

Generator

- Voltage level _____
- Frequency _____
- Main breaker _____

Control Panel

- Alarm lights _____
- Panel lights _____
- Meters _____
- Gauges _____
- Hour meter _____

Auto Transfer Switch

- Contacts _____

- Overheating _____
- Connections _____
- Lights _____
- Make _____
- Model _____
- S/N _____
- Spec _____

Breaker

- On/Off _____
- **Fuel Tank Size**

Test for 30 minutes? _____
Per NFPA 110, 8.3.2.1

Transfer Time _____

Service recommended

The equipment operates normally. The following service procedures are due:

Oil Change _____ Fuel Filter _____ Air Filter _____ Tune-up _____ Radiator Service _____

Belt/hose replacement _____ Battery Replacement _____ Valve Lash Adjustment _____

ATS Service _____ Loadbank _____ 4-hr Load Test _____ Fuel Test _____

Repairs recommended

The following repairs are recommended in order to restore the equipment to reliable service.

Authorized

by _____ Technician _____ Date _____