

**PART II – HEALTH CARE FACILITIES CODE REQUIREMENTS**

**K-916**

**Remote Annunciators**

## K916

### **Electrical Systems – Essential Electric System Alarm Annunciator**

A remote annunciator that is **storage battery powered** is provided to operate outside of the generating room in a location readily observed by operating personnel. The annunciator is hard-wired to indicate alarm conditions of the emergency power source. A centralized computer system (e.g., building information system) is not to be substituted for the alarm annunciator. 6.4.1.1.17, 6.4.1.1.17.5 (NFPA 99)

**Storage battery powered** does not mean battery backup.

The remote annunciator is “hard wired” to the generator’s cranking battery through the generator’s control panel.

The cranking battery is closely monitored by the battery charger and the remote annunciator if NFPA 110 and 99 have been observed during acquisition and installation.

## K916

### **Electrical Systems – Essential Electric System Alarm Annunciator**

A remote annunciator that is storage battery powered is provided **to operate outside of the generating room in a location readily observed by operating personnel.** The annunciator is hard-wired to indicate alarm conditions of the emergency power source. A centralized computer system (e.g., building information system) is not to be substituted for the alarm annunciator. 6.4.1.1.17, 6.4.1.1.17.5 (NFPA 99)

The annunciator cannot be mounted in a closet, behind doors, or in the generator room. In practice, it should be in an occupied part of the building in order to be readily observable.

We have moved annunciators to occupied parts of a building after a wing was shut down and no longer regularly occupied.

## K916

### **Electrical Systems – Essential Electric System Alarm Annunciator**

A remote annunciator that is storage battery powered is provided to operate outside of the generating room in a location readily observed by operating personnel. The annunciator is **hard-wired to indicate alarm conditions** of the emergency power source. A **centralized computer system** (e.g., building information system) is not to be substituted for the alarm annunciator. 6.4.1.1.17, 6.4.1.1.17.5 (NFPA 99)

An annunciator may not use WiFi to signal a fault.

In older systems individual wires conduct fault signals to the annunciator. Recently manufacturers use a USB connection, but it is still solidly wired.

Centralized computer systems may be used as auxiliary, but they cannot replace the hard-wired source for alarm signals.

All information expressed by Standby Power Solutions, LLC or its officers is strictly the opinion of Standby Power Solutions, LLC.

Standby Power Solutions, LLC disclaims any liability for any personal injury, property, or other damages of any nature whatsoever, whether special, indirect, consequential or compensatory directly or indirectly resulting from the publication, use of, or reliance on this website or any information derived thereof. Standby Power Solutions, LLC also makes no guaranty or warranty as to the accuracy or completeness of any information contained herein. Anyone using this website should rely on his or her own independent judgment, or as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances. ©2021 by Standby Power Solutions, LLC. All rights reserved. Do not reproduce without express written permission.